

Primary Laboratories, Inc.

7423 Lee Davis Road • Mechanicsville, VA 23111 • Telephone (804) 559-9004 • Fax (804) 559-9306

RECEIVED

JUN 09 2011

PRO

ANALYTICAL LABORATORY REPORT

17-May-11

Montross WWTP
Attn: Kevin Spruth
160 Lyells Street
Montross, VA 22520

Date Received: 11-May-11
Date Sampled: 9-May-11
Work Order No: 1105101-01
Client ID: **Outfall 001 Composite**

Test Description	Final Result	Reporting Limit	Units of Measure	Method Numbers*	Date Analyzed	Tech. Initials
Ammonia	0.16	0.01	mg/L	4500NH3 F	16-May-11 at 12:00	NA
CBOD	<5.0	5.0	mg/L	5210 B	11-May-11 at 9:00	NA
TKN	0.64	0.20	mg/L	4500-N _{org} C	16-May-11 at 9:00	NA

Date Sampled: 10-May-11
Work Order No: 1105101-02
Client ID: **Outfall 001 Composite**

Test Description	Final Result	Reporting Limit	Units of Measure	Method Numbers*	Date Analyzed	Tech. Initials
TKN	0.78	0.20	mg/L	4500-N _{org} C	16-May-11 at 9:00	NA
CBOD	<5.0	5.0	mg/L	5210 B	11-May-11 at 9:00	NA

Primary Laboratories Results


17-May-11

Date Sampled: 11-May-11
Work Order No: 1105101-03
Client ID: Outfall 001 Grab

Test Description	Final Result	Reporting Limit	Units of Measure	Method Numbers*	Date Analyzed	Tech. Initials
Fecal Coliform	<2	2	MPN/100ml	9221E	11-May-11 at 15:15	MS

*All methods are from Standard Methods 18th Edition, unless otherwise noted.

Signature: _____


Parry L. Bragg
Laboratory Manager


Date: _____



These analytical results are based upon materials provided by the client and are intended for the exclusive use of the client. These analytical results represent the best judgement of Primary Laboratories, Inc. Primary Laboratories, Inc. assumes no responsibility, express or implied, as to the interpretation of the analytical results contained in this report. This report is not to be reproduced except with the written approval of Primary Laboratories, Inc.

Primary Laboratories, Inc.

7423 Lee Davis Road • Mechanicsville, VA 23111 • Telephone (804) 559-9004 • Fax (804) 559-9306

**ANALYTICAL LABORATORY REPORT**

19-May-11

Montross WWTP
Attn: Kevin Spruth
160 Lyells Street
Montross, VA 22520

Date Received: 12-May-11
Date Sampled: 11-May-11
Work Order No: 1105120-01
Client ID: **Outfall 001 Composite**

Test Description	Final Result	Reporting Limit	Units of Measure	Method Numbers*	Date Analyzed	Tech. Initials
CBOD	<5.0	5.0	mg/L	5210 B	13-May-11 at 10:30	NA
TKN	1.0	0.2	mg/L	4500-N _{org} C	16-May-11 at 9:00	NA

Date Sampled: 12-May-11
Work Order No: 1105120-01
Client ID: **Outfall 001 Grab**

Test Description	Final Result	Reporting Limit	Units of Measure	Method Numbers*	Date Analyzed	Tech. Initials
E Coli	1.0	1.0	MPN/100ml	Colilert	12-May-11 at 14:40	MS
Fecal Coliform	<2	2	MPN/100ml	9221E	12-May-11 at 14:30	MS

*All methods are from Standard Methods 18th Edition, unless otherwise noted.

Signature: 

Perry L. Bragg
Laboratory Manager

Date: 5/19/11

These analytical results are based upon materials provided by the client and are intended for the exclusive use of the client. These analytical results represent the best judgement of Primary Laboratories, Inc. Primary Laboratories, Inc. assumes no responsibility, express or implied, as to the interpretation of the analytical results contained in this report. This report is not to be reproduced except with the written approval of Primary Laboratories, Inc.